

**Application Type:** Minor Engineering Change  
**Applicant Name:** Robert W. Murray, Applicant  
**Location of Project:** 10 New England Executive Park  
**Application Date:** August 16, 2006    **Hearing Date:** September 7, 2006  
**Decision:**  Approved    Denied    Withdrawn    No Decision   **Date:**

BOARD		COMMENTS	DATE RECEIVED
Board of Selectmen	Original		
	Revised		
Inspector of Buildings	Original	Faverable	9-6-06
	Revised		
DPW/ Engineering	Original	Faverable	8-23-06
	Revised		
Police Department	Original		
	Revised		
Fire Department	Original	See Comments	8-24-06
	Revised		
Board of Health	Original	Faverable	9-6-06
	Revised		
Conservation Commission	Original		
	Revised		

**Subject:** Fw: 10 Neep- MEC

**From:** "Anthony Fields" <afields@burlmass.org>

**Date:** Wed, 6 Sep 2006 15:57:48 -0400

**To:** "Kristin Hoffman" <khoffman@burlmass.org>, <jgelinas@burlmass.org>

**CC:** "Phyllis Etsell" <phyllis@murrayhills.com>

----- Original Message -----

**From:** John Clancy

**To:** Anthony Fields

**Cc:** Mark T Vaughan ; John Clancy

**Sent:** Wednesday, September 06, 2006 4:58 PM

**Subject:** 10 Neep- MEC

Tony: I have reviewed the proposed changes and have no objection. Thanks- John

**Subject:** 10 New England Executive Park - MEC (4160)

**From:** "Tom Hayes" <thayes@burlmass.org>

**Date:** Wed, 23 Aug 2006 08:47:48 -0400

**To:** "Anthony Fields" <afields@burlmass.org>, "Bernie Schipelliti" <bschipelliti@burlmass.org>, "Heidi Porter" <hporter@burlmass.org>, "Janis Critch" <jcritch@burlmass.org>, "Jen Gelinis" <jgelinas@burlmass.org>, "John Clancy" <jclancy@burlmass.org>, "John Keeley" <jkeeley@burlmass.org>, "Kristin Hoffman" <khoffman@burlmass.org>, "Lee Callahan" <lcallahan@burlmass.org>, "Mike Hanafin" <mhanafin@burlmass.org>, "Pauline Crusco" <pcrusco@burlmass.org>, "Robert Mercier" <rmercier@burlmass.org>, "Sharon Mastenbrook" <smastenbrook@burlmass.org>, "Syamal Chaudhuri" <schaudhuri@burlmass.org>, "Thomas Hayes," <thayes@burlmass.org>, "Thomas Hickey" <thickey@burlmass.org>

I have reviewed the above application and have no significant comments or concerns.

Thomas F. Hayes, P.E.  
Town Engineer  
25 Center Street  
Burlington, MA 01803  
781 270-1640  
781-238-4693 fax  
THayes@burlmass.org

PLAN REVIEW REPORT FORM

Recommendations from the Fire Department regarding the application for approval of a:

- |   |  |
|---|--|
| <input type="checkbox"/> Site Plan        | <input type="checkbox"/> Definitive Subdivision              |
| <input type="checkbox"/> Site Plan Waiver | <input type="checkbox"/> Revised Plans                       |
| <input type="checkbox"/> Special Permit   | <input checked="" type="checkbox"/> Minor Engineering Change |

entitled: 10 NEW ENGLAND EXECUTIVE PARK

date: August 21, 2006

---

---

The Fire Department recommends:

- Approval as submitted                       Not applicable  
 Approval with the following modifications:

1. The post indicator valve located adjacent to the new proposed entrance must remain accessible.
2. 12' feet clearance required under carport for ambulance access.
3. Flammable storage permit required for propane storage.
4. Suitable physical protection required to protect against vehicular impact for generator and propane tank.
5. Dumpster permit required per 527 CMR 34.03.

Chief Lee Callahan  
Authorized Signature

August 24, 2006  
Date

**Subject:** Fw: 10 NEEP

**From:** "Anthony Fields" <afields@burlmass.org>

**Date:** Wed, 6 Sep 2006 12:11:28 -0400

**To:** "Phyllis Etsell" <phyllis@murrayhills.com>, <jgelinas@burlmass.org>

----- Original Message -----

From: "Sharon Mastenbrook" <smastenbrook@burlmass.org>

To: "Anthony Fields" <afields@burlmass.org>

Cc: "Kristin Hoffman" <khoffman@burlmass.org>; "Heidi Porter" <hporter@burlmass.org>

Sent: Wednesday, August 30, 2006 4:52 PM

Subject: 10 NEEP

The Board of Health has no comments on this MEC.

--

*/Sharon Walker Mastenbrook, MA, MS, RS/*

*/Director of Public Health/*

*/Burlington// Board of Health/*

*/61 Center Street/*

*/Burlington//, MA 01803/*

*/781-270-1954/*

*/fax 781-273-7687/*